

**CERTIFICATION OF COMPLIANCE WITH PARKING LOT ILLUMINATION
STANDARDS IN CHAPTER 8C OF THE CODE OF MIAMI-DADE COUNTY**

Date: 02/22/2021


RE: Case No.: _____ Folio: 01-4139-031-0001 (REF)

Property Address: 1915 BRICKELL AVE MIAMI, FL 33129

Building Description: Two buildings: slab on grade foundation, CBS walls, flat roof

1. I am a Florida registered professional engineer or architect with an active license.
2. On 02/22, 2021, at 6:40 pm, I measured the level of illumination in the parking lot (s) serving the above referenced building.
3. Maximum 6.25 foot candle per SF, Minimum 1.14 foot candle per SF, Minimum to Maximum ratio 1.00 : 5.48, foot candle 2.77 average per SF.
4. The level of illumination provided in the parking lot (s) (meets) does not meet the minimum standards for the occupancy classification of the building as established in Section 8C-3 of the Code of Miami-Dade County.

02/22/21
Signature and Seal
of Architect or Engineer

A circular professional seal for Roberto Barreiro, a Professional Engineer in the State of Florida. The seal contains the text: "ROBERTO BARREIRO", "LICENSE", "No. 68383", "STATE OF FLORIDA", and "PROFESSIONAL ENGINEER". The seal is partially obscured by a handwritten signature and the date "02/22/21".

ROBERTO BARREIRO, P.E.
(Print Name)